

PLICSMOBILE/PLICSMOBILE T61

Version, available since	Description
1.00, 05/2011	First sales version
1.10, 12/2011	<p>New functions:</p> <ul style="list-style-type: none"> – Optimized process, message transmission – Support for power pack PM-BATT – Transmission of the remaining capacitance from the power pack – Transmission of the signal strength <p>Error corrections:</p> <ul style="list-style-type: none"> – Pressure transmitter with adjustment unit "m" was updated – Multiple measured value transmission with "Measured value-controlled message" in conjunction with sensor value and plics® sensors
1.11, 06/2012	<p>New functions:</p> <ul style="list-style-type: none"> – Improvement of the stability in case of network problems <p>Error corrections:</p> <ul style="list-style-type: none"> – SIM pin with leading "0" caused problems – Unit of the scaled value of a PA sensor was not always transferred correctly – Measured value/time-controlled event was not triggered correctly
1.12, 07/2012	<p>Error corrections:</p> <ul style="list-style-type: none"> – Energy saving mode was not activated with non-connected sensor – Dial-up for incoming dial-up connections improved

Version, available since	Description
1.13, 11/2012	<p>New functions:</p> <ul style="list-style-type: none"> – The integrated PLICSMOBILE version uses now the instrument serial number of the sensor for message transmission – Reading out of the IMEI number – Reading out of the own telephone number from the SIM card <p>Error corrections:</p> <ul style="list-style-type: none"> – Problems when sending SMS messages removed – Problem when incrementing the counter of the network statistics in conjunction with the energy saving mode removed
1.14, 06/2013	<p>Error corrections:</p> <ul style="list-style-type: none"> – Instrument warm start through CSD caused malfunction – Internal communication problems removed
1.15, 09/2014	<p>New functions:</p> <ul style="list-style-type: none"> – E-Mail encryption with TLS 1.2 – Port numbers for SMTP, HTTP and POP3 adjustable – SIM card ID is transmitted with WEB VV events – Cell information is transmitted with WEB VV events – IMEI is transmitted with WEB VV events – More entries in the event memory with faulty transmission attempts – Standard settings pre-configured for dial-out with VEGA SIM cards after “Restore basic settings”

Legend:

Name	Description
Version	Compatibility version.Function extension version.Error correction version
available since	Month/Year